

Microbiology Log Sheet

Operational Monitoring

Town:

Month:

Year:

Date Sampled	Sample Location	Incubation				Presence for Total Coliforms	Presence for E. coli	Chlorine Residual	Operator
		Time Put In	Time Put Out	Temp. 35°C - 37°C	Period 'In' (hours)	Is there a blue/green colour change present? Yes/No	After adding Indole is there a red ring? Yes/No	mg/l at time of collection	

Bell: LLR @ WTP - 1/wk, LLR @ Cody Hill - 1/wk, N - 1/wk. **Chinchilla:** CSP10 Treated Water Tank @ WTP - 1/wk, LLR @ Colamba St. - 1/wk, N - 2/wk. **Condamine:** LLR @ WTP - 1/wk, N - 1/wk.

Dalby: CWT @ WTP - 1/wk, LLR @ Edward St. - 1/wk, N - 3/wk. **Miles:** CWT at WTP - 1/wk, LLR at WTP - 1/wk, N 1/wk. **Wandoan:** WTP - 1/wk, Tower Exit - 1/wk, N - 1/wk.

Warra: Final Treated from CWT @ WTP (WRW5) - 1/wk, Tower - 1/wk, N - 1/wk. **Tara:** LLR @ WTP - 1/wk, N - 1/wk.

Jandowae: Final Treated @ WTP* (JAW9) - 1/wk, Tower - 1/wk, N - 1/wk, Bores WTP, 1, 2, 6* (JAW2 & JAW10) - 1/wk (*All bores - 1/day for 1 week when operating then 1/wk if nothing detected)

POSITIVE E. COLI - IMMEDIATELY CONTACT WATER TREATMENT PRINCIPAL (OR ACTING WTP) AND SUPERVISOR BY PHONE AND E-MAIL. REFER TO THE DWQMP INCIDENT REPORT TO DETERMINE RISK LEVEL